Certificate of Test

Quote No.: NC7997 REPORT No.: FNC12148B

COMBUSTIBILITY TEST FOR MATERIALS IN ACCORDANCE WITH AS 1530.1-1994

TRADE NAME: Austral Glass Bricks

SPONSOR: Brickworks Building Products Pty Ltd

738 – 780 Wallgrove Road HORSLEY PARK NSW 2175

AUSTRALIA

DESCRIPTION OF

TEST SAMPLE: The sponsor described the tested specimen as a Austral glass brick comprised of soda lime

glass.

Nominal thickness: 50 mm

Nominal density: 250 kg/m³

Colour: blue

TEST PROCEDURE: Five (5) samples were tested in accordance with Australian Standard 1530 Methods for

fire tests on building materials, components and structures, Part 1- 1994: Combustibility

Test for Materials.

An alternative suitable insulating material was used to fill the annular space between the

furnace tubes, as specified in Clause 4.2 of ISO 1182:2010.

DESIGNATION: The material is NOT deemed COMBUSTIBLE according to the test criteria specified in

Clause 3.4 of AS 1530.1-1994.

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

DATE OF TEST: 10 April 2018

Issued on the 18th day of October 2021 without alterations or additions. Supersedes CSIRO Report FNC12148A issued on 2nd day of July 2018.

B. Rosey

Faustin Molina

Testing Officer Team Leader, Fire Testing and Assessments

Brett Roddy

Copyright CSIRO 2021 ©. Copying or alteration of this report without written authorisation from CSIRO is forbidden.

NATA
WORLD RECOGNISED

NATA Accredited Laboratory Number: 165 Corporate Site No 3625

Accredited for compliance with ISO/IEC 17025 - Testing.

CSIRO INFRASTRUCTURE TECHNOLOGIES

